



**Township of Maple Shade**

**Office of the Fire Marshal**

200 Stiles Avenue  
Maple Shade, NJ 08052  
856-779-9610

**EMERGENCY AND EXIT LIGHTING LOG**

**30 SECONDS PER MONTH / 1 HOUR PER YEAR**

**BUSINESS NAME:** \_\_\_\_\_

**BUSINESS ADDRESS:** \_\_\_\_\_

	EXIT SIGNS OPERATIONAL	EMERGENCY OPERATIONAL	TESTED BY	EXPLAIN "NO" & DATE REPLACED
<b>JANUARY</b>				
<b>FEBRUARY</b>				
<b>MARCH</b>				
<b>APRIL</b>				
<b>MAY</b>				
<b>JUNE</b>				
<b>JULY</b>				
<b>AUGUST</b>				
<b>SEPTEMBER</b>				
<b>OCTOBER</b>				
<b>NOVEMBER</b>				
<b>DECEMBER</b>				

THE ONE (1) HOUR ANNUAL TESTING OF THE EMERGENCY AND EXIT LIGHTING SYSTEM WAS CONDUCTED ON \_\_\_\_\_ AND THE NOTED DEFICIENCIES ARE:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

REPAIRS WERE COMPLETED BY: \_\_\_\_\_ DATE: \_\_\_\_\_